



TWIN CREEK WATER SUPPLY CORPORATION

PO BOX 88

NEW BADEN TEXAS 77870

Phone: 1-(979) 828-5385 * Fax: 1-(979) 828-2445

Web: www.twincreekwsc.org * Email: office@twincreekwsc.org

ADDENDA #14 TO TARIFF

Section E. 28. Member's Responsibility e.) (page 29):

Change Entire Paragraph From:

The Corporation shall require each Member to have a cut-off valve on the Members' side of the meter as close as physically possible to the meter, but no closer than 24" from the meter for the purposes of isolating the Member's service pipeline and plumbing facilities from the Corporation's water pressure. As a condition of receiving water service, all new accounts must have this cut-off valve installed before the Customer Service Inspection (CSI) is performed and passed or water service will not be activated. The above is also required anytime a CSI is triggered for the approved reasons. **The Member's use of the Corporation's curb stop or other similar valve for such purposes is prohibited. Any damage to the Corporation's equipment shall be subject to service charges.**

Change Entire Paragraph To:

When a CSI is triggered, Twin Creek WSC (TCWSC) requires, as a "Requirement of Membership", to have a shut-off valve located on the Members' side of the meter box. This allows the Member the ability to isolate their system in case of an emergency and eliminates any need to use TCWSC shut-off valves located inside the meter box. The Members' shut-off valve must be located between 24" to 48" from the edge of TCWSC's meter box. If any obstruction, roadway, or for any other valid reasons prevent meeting this distance, please contact the TCWSC office for further guidance as to any variance of the distance requirement. If upon inspection, the shut-off location does not meet the requirements, a trip fee charge will be generated. Use of anything inside TCWSC's meter box is prohibited and can only be used by TCWSC personnel. Any damages to the Corporation's equipment shall be subject to service charges.

Adopted by The Board of Directors at the regular Board Meeting held on June 13, 2023 at 2:00 PM approved the change.